

4. WHERE FIRE PROTECTION WATER SUPPLY IS DEDICATED FIRE PROTECTION WATER, BACKFLOW PREVENTER IS NOT

6. PROVIDE FLOOR DRAIN TO SANITARY SEWER NEAR BFP. ROUTE DRAIN PIPING TO MINIMIZE A TRIPPING HAZARD.

7. BFP INSTALLED MORE THAN 5 FEET ABOVE FLOOR SHALL BE PROVIDED WITH A PLATFORM CAPABLE OF SUPPORTING

REQUIRED.

5. SIZE FIRE LINE BFP TO MATCH ALARM CHECK VALVE SIZE.

A TESTER OR MAINTENANCE PERSON (UPC REQUIREMENT).

DRAWING DEVELOPED FOR ML-3 PROJECTS. FOR ML-1/ML-2, ADDITIONAL REQUIREMENTS AND QA REVIEWS ARE REQUIRED. (REMOVE THIS NOTE WHEN IN-SERTED INTO A DRAWING PACK-

8-30-02 U NEW SHEET REP AT JW JW TO DATE DESCRIPTION FACILITY & WASTE OPERATIONS SYSTEMS ENGINEERING & MAINTENANCE LANL ENGINEERING MANUAL DRAWN DESIGN ATRUILLD SPRINKLER SYSTEM RISER DETAIL CHECKED DISCIPLINE POC: JULIA VOOD STANDARDS MANAGER: TOBIN ORUCH CHAPTER 2 ST-D4010-1

AGE).